Energy performance certificate (EPC)

18 Newman Court Barber Road BASINGSTOKE RG22 4BW

Energy rating

Valid until: 22 August 2032

Certificate number: 2528-3019-8208-9382-5200

Property type

Mid-floor flat

Total floor area

69 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read <u>guidance</u> for <u>landlords</u> on the <u>regulations</u> and <u>exemptions</u> (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Timber frame, as built, insulated (assumed)	Very good
Window	Fully double glazed	Good
Main heating	Community scheme	Good
Main heating control	Charging system linked to use of community heating, TRVs	Good
Hot water	Community scheme	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(other premises below)	N/A
Secondary heating	None	N/A

Primary energy use

produces

The primary energy use for this property per year is 153 kilowatt hours per square metre (kWh/m2).

Environmental impact of this property This property's current environmental impact rating is C. It has the potential to be C.		This property produces	1.9 tonnes of CO2
		This property's potential production	1.9 tonnes of CO2
Properties are rated in a scale from A to G based on how much carbon dioxide (CO2) they produce. Properties with an A rating produce less CO2		By making the recommender could reduce this property's 0.0 tonnes per year. This with environment.	CO2 emissions by
than G rated properties. An average household 6 tonnes of CO2		Environmental impact rating assumptions about average energy use. They may not r	occupancy and

consumed by the people living at the property.

Improve this property's energy performance

The assessor did not make any recommendations for this property.

<u>Simple Energy Advice has guidance on improving a property's energy use.</u>
https://www.simpleenergyadvice.org.uk/)

Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£432
Potential saving	£0

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you complete each recommended step in order.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u>

(https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used
Space heating	3469 kWh per year
Water heating	2090 kWh per year
Potential energy say	vings by installing

The assessor did not find any opportunities to save energy by installing insulation in this

insulation

property.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name Michael O'Shea Telephone 01256 811730

Email <u>moshea@winkworth.co.uk</u>

Accreditation scheme contact details

Accreditation scheme Elmhurst Energy Systems Ltd

Assessor ID EES/002843
Telephone 01455 883 250
Email enquiries@elmhurstenergy.co.uk

Assessment details

Assessor's declaration

Date of assessment

Date of certificate

No related party
22 August 2022
23 August 2022

Type of assessment RdSAP